



## Consumer Confidence Report For Calendar Year 2015

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alguien que lo entienda bien.

### I. Public Water System (PWS) Information

<b>PWS ID Number</b>	<b>PWS Name</b>		
AZ04 - 09060	Wonderland Acres Domestic Water Improvement District		
<b>Contact Person and Title</b>		<b>Phone Number</b>	<b>E-Mail Address</b>
Barry Harville, Operator		928-368-6280	kleansweepops@yahoo.com
<p>We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>Stephanie Irwin CPA</u> at <u>928-367-6621</u> for additional opportunity and meeting dates and times.</p>			

### II. Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

The report must contain a brief explanation regarding contaminants which may reasonably be expected to be found in drinking water. This explanation may include the language of paragraph 40 CFR 141.153 (h)(1)(iii) shown below, or the system may use their own comparable language:

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s): | 5 wells

### III. Consecutive Connection Sources

A public water system that receives some or all of its finished water from one or more wholesale systems by means of a direct connection or through the distribution system of one or more consecutive systems. Systems that purchase water from another system report regulated contaminants detected from the source water supply in a separate table.

PWS ID #

### IV. Drinking Water Contaminants

Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

#### V. Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

#### VI. Source Water Assessment

**N/A**

#### VII. Definitions

AL = Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements.

MCL = Maximum Contaminant Level – The highest level of a contaminant that is allowed in drinking water.

MCLG = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health.

MFL = Million fibers per liter.

MRDL = Maximum Residual Disinfectant Level. The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap.

MRDLG = Maximum Residual Disinfectant Level Goal. The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur.

MREM = Millirems per year – a measure of radiation absorbed by the body.

NA = Not Applicable, sampling was not completed by regulation or was not required.

NTU = Nephelometric Turbidity Units, a measure of water clarity.

PCi/L = Picocuries per liter - picocuries per liter is a measure of the radioactivity in water.

PPM = Parts per million or Milligrams per liter (mg/L).

PPB = Parts per billion or Micrograms per liter (µg/L).

PPT = Parts per trillion or Nanograms per liter.

PPQ = Parts per quadrillion or Picograms per liter.

TT = Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

ppm x 1000 = ppb
------------------

ppb x 1000 = ppt
------------------

ppt x 1000 = ppq
------------------

#### VIII. Health Effects Language

**Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. "High nitrate levels in drinking water can cause blue baby syndrome." Nitrate levels may rise quickly for short periods-of-time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

If **arsenic** is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels

of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**LEAD:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wonderland Domestic Water Improvement District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## IX. Water Quality Data

Microbiological	Violation Y or N	Number of Samples Present OR Highest Level Detected	Absent (A) or Present (P) OR Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Total Coliform Bacteria</b> (System takes ≥ 40 monthly samples) 5% of monthly samples are positive; (System takes ≤ 40 monthly samples) 1 positive monthly sample	N		A	0	0	2015	Naturally Present in Environment
<b>Fecal coliform and E. Coli</b> (TC Rule)	N		A	0	0	2015	Human and animal fecal waste
<b>Fecal Indicators</b> (E. coli, enterococci or coliphage) (GW Rule)	N		A	TT	n/a		Human and animal fecal waste
<b>Total Organic Carbon</b> (ppm)	N		A	TT	n/a		Naturally present in the environment
<b>Turbidity</b> (NTU), surface water only	N		A	TT	n/a		Soil Runoff
Disinfectants	Violation Y or N	Running Annual Average (RAA)	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Chloramines (ppm)</b>	N		A	MRDL = 4	MRDLG = 4		Water additive used to control microbes
<b>Chlorine (ppm)</b>	N	.19	.15-.35	MRDL = 4	MRDLG = 4	2015	Water additive used to control microbes
<b>Chloride dioxide (ppb)</b>	N			MRDL = 800	MRDLG = 800		Water additive used to control microbes
Disinfection By-Products	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
<b>Haloacetic Acids (ppb) (HAA5)</b>	N		<0.0010	60	n/a	08-2015	Byproduct of drinking water disinfection
<b>Total Trihalomethanes (ppb) (TTHM)</b>	N	.0047	.0047-.0020	80	n/a	08-2015	Byproduct of drinking water disinfection
<b>Bromate (ppb)</b>	N	.00099	.0005-.0058	10	0	2012	Byproduct of drinking water disinfection
<b>Chlorite (ppm)</b>	N	.0098	.001-.001	1	0.8	2012	Byproduct of drinking water disinfection
Lead & Copper	Violation Y or N	90 <sup>th</sup> Percentile AND Number of Samples Over the AL	Range of All Samples (L-H)	AL	ALG	Sample Month & Year	Likely Source of Contamination
<b>Copper (ppm)</b>	N	90 <sup>th</sup> Percentile =	0.0-.18	AL = 1.3	ALG = 1.3	9-13	Corrosion of household plumbing systems; erosion of natural deposits

<b>Lead (ppb)</b>	N	90 <sup>th</sup> Percentile =	.0012-.001-86	AL = .015	AL=0.015	2013-2016	Corrosion of household plumbing systems; erosion of natural deposits
<b>Radionuclides</b>	<b>Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>Beta / photon emitters (mrem/yr.)</b>	N	0	0	4	0	05-2015	Decay of natural and man-made deposits
<b>Alpha emitters (pCi/L) (this is Gross Alpha 4002)</b>	N	0	0	15	0	05-2015	Erosion of natural deposits
<b>Combined Radium 226 &amp; 228 (pCi/L)</b>	N	3.7	2.4-5.0	5	0	05-2015	Erosion of natural deposits
<b>Uranium (ug/L)</b>	N	0	0	30	0	05-2015	Erosion of natural deposits
<b>Inorganic Chemicals (IOC)</b>	<b>Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>Antimony (ppb)</b>	N		.001	6	6	09-2012	Discharge from petroleum refineries; fire retardants; ceramics, electronics and solder
<b>Arsenic (ppb)</b>	N		.001	10	0	09-2012	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
<b>Asbestos (MFL)</b>	N		.02	7	7	09-2012	Decay of asbestos cement water mains; Erosion of natural deposits
<b>Barium (ppm)</b>	N	.052	.13-.052	2	2	09-2012	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
<b>Beryllium (ppb)</b>	N		.001	4	4	09-2012	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
<b>Cadmium (ppb)</b>	N		.0005	5	5	09-2012	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
<b>Chromium (ppb)</b>	N	.0011	.0011	100	100	09-2012	Discharge from steel and pulp mills; Erosion of natural deposits
<b>Cyanide (ppb)</b>	N		.025	200	200	09-2012	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
<b>Fluoride (ppm)</b>	N	.087	.097-.87	4	4	09-2012	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
<b>Mercury (ppb)</b>	N		.0002	2	2	09-2012	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland.
<b>Nitrate (ppm)</b>	N	1.5	.48-1.5	10	10	09-2012	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Nitrite (ppm)</b>	N	1.5	.48-1.5	1	1	09-2012	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural

							deposits
<b>Selenium (ppb)</b>	N		.005	50	50	09-2012	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Sodium (ppm)</b>	N	24	21-24	N/A	N/A	09-2012	N/A
<b>Thallium (ppb)</b>	N		.001	2	0.5	09-2012	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
<b>Synthetic Organic Chemicals (SOC)</b>	<b>Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>2,4-D (ppb)</b>	N		.001	70	70	05-2015	Runoff from herbicide used on row crops
<b>2,4,5-TP (a.k.a. Silvex) (ppb)</b>	N		.002	50	50	05-2015	Residue of banned herbicide
<b>Acrylamide</b>	N		0	TT	0	05-2015	Added to water during sewage / wastewater treatment
<b>Alachlor (ppb)</b>	N		.001	2	0	05-2015	Runoff from herbicide used on row crops
<b>Atrazine (ppb)</b>	N		.1	3	3	05-2015	Runoff from herbicide used on row crops
<b>Benzo (a) pyrene (PAH) (ppt)</b>	N		.00002	200	0	05-2015	Leaching from linings of water storage tanks and distribution lines
<b>Carbofuran (ppb)</b>	N		.9	40	40	05-2015	Leaching of soil fumigant used on rice and alfalfa
<b>Chlordane (ppb)</b>	N		.00001	2	0	05-2015	Residue of banned termiticide
<b>Dalapon (ppb)</b>	N		.001	200	200	05-2015	Runoff from herbicide used on rights of way
<b>Di (2-ethylhexyl) adipate (ppb)</b>	N		.0006	400	400	05-2015	Discharge from chemical factories
<b>Di (2-ethylhexyl) phthalate (ppb)</b>	N		.	6	0	05-2015	Discharge from rubber and chemical factories
<b>Dibromochloropropane (ppt)</b>	N		.00001	200	0	05-2015	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
<b>Dinoseb (ppb)</b>	N		.0002	7	7	05-2015	Runoff from herbicide used on soybeans and vegetables
<b>Diquat (ppb)</b>	N		.0004	20	20	05-2015	Runoff from herbicide use
<b>Dioxin [a.k.a. 2,3,7,8-TCDD] (ppq)</b>	N		0	30	0	05-2015	Emissions from waste incineration and other combustion; discharge from chemical factories
<b>Endothall (ppb)</b>	N		9	100	100	05-2015	Runoff from herbicide use
<b>Endrin (ppb)</b>	N		.00001	2	2	05-2015	Residue of banned insecticide
<b>Epichlorohydrin</b>	N		.00001	TT	0	05-2015	Discharge from industrial chemical factories; an impurity of some water treatment chemicals
<b>Ethylene dibromide (ppt)</b>	N		.00001	50	0	05-2015	Discharge from petroleum refineries

<b>Glyphosate (ppb)</b>	N		6	700	700	05-2015	Runoff from herbicide use
<b>Heptachlor (ppt)</b>	N		.00001	400	0	05-2015	Residue of banned termiticide
<b>Heptachlor epoxide (ppt)</b>	N		.00001	200	0	05-2015	Breakdown of heptachlor
<b>Hexachlorobenzene (ppb)</b>	N		.00005	1	0	05-2015	Discharge from metal refineries and agricultural chemical factories
<b>Hexachlorocyclopentadiene (ppb)</b>	N		.0001	50	50	05-2015	Discharge from chemical factories
<b>Lindane (ppt)</b>	N		.00001	200	200	05-2015	Runoff/leaching from insecticide used on cattle, lumber, gardens
<b>Methoxychlor (ppb)</b>	N		.00005	40	40	05-2015	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa,
<b>Oxamyl (a.k.a. Vydate) (ppb)</b>	N		.0005	200	200	05-2015	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
<b>PCBs [Polychlorinated biphenyls] (ppt)</b>	N		100	500	0	05-2015	Runoff from landfills; discharge of waste chemicals
<b>Pentachlorophenol (ppb)</b>	N		.00004	1	0	05-2015-	Discharge from wood preserving factories
<b>Picloram (ppb)</b>	N		.0001	500	500	05-2015	Herbicide runoff
<b>Simazine (ppb)</b>	N		.00005	4	4	05-2015	Herbicide runoff
<b>Toxaphene (ppb)</b>	N		.0005	3	0	05-2015	Runoff/leaching from insecticide used on cotton and cattle
<b>Volatile Organic Chemicals (VOC)</b>	<b>Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>Benzene (ppb)</b>	N		.0005	5	0	05-2015	Discharge from factories; leaching from gas storage tanks and landfills
<b>Carbon tetrachloride (ppb)</b>	N		.0005	5	0	05-2015	Discharge from chemical plants and other industrial activities
<b>Chlorobenzene (ppb)</b>	N		.0005	100	100	05-2015	Discharge from chemical and agricultural chemical factories
<b>o-Dichlorobenzene (ppb)</b>	N		.0005	600	600	05-2015	Discharge from industrial chemical factories
<b>p-Dichlorobenzene (ppb)</b>	N		.0005	75	75	05-2015	Discharge from industrial chemical factories
<b>1,2-Dichloroethane (ppb)</b>	N		.0005	5	0	05-2015	Discharge from industrial chemical factories
<b>1,1-Dichloroethylene (ppb)</b>	N		.0005	7	7	05-2015	Discharge from industrial chemical factories
<b>cis-1,2-Dichloroethylene</b>	N		.0005	70	70	05-2015	Discharge from

(ppb)							industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	N		.0005	100	100	05-2015	Discharge from industrial chemical factories
Dichloromethane (ppb)	N		.0005	5	0	05-2015	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	N		.0005	5	0	05-2015	Discharge from industrial chemical factories
Ethylbenzene (ppb)	N		.0005	700	700	05-2015	Discharge from petroleum refineries
Styrene (ppb)	N		.0005	100	100	05-2015	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	N		.0005	5	0	05-2015	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	N		.0005	70	70	05-2015	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	N		.0005	200	200	05-2015	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	N		.0005	5	3	05-2015	Discharge from industrial chemical factories
Trichloroethylene (ppb)	N		.0005	5	0	05-2015	Discharge from metal degreasing sites and other factories
Toluene (ppm)	N		.0005	1	1	05-2015	Discharge from petroleum factories
Vinyl Chloride (ppb)	N		.0005	2	0	05-2015	Leaching from PVC piping; discharge from chemical factories
Xylenes (ppm)	N		.0005	10	10	05-2015	Discharge from petroleum or chemical factories

#### XI. Violations

Type / Description	Compliance Period	Corrective Actions taken by PWS
NONE		

An explanation of the violation(s) in the above table, the steps taken to resolve the violation(s) and any required health effects information are required to be included with this report. (Attach copy of Public Notice if available.)